

Via email: kboyer@centria.com

February 5, 2009

Mr. Keith D. Boyer, P.E.
Director, Design and Development
CENTRIA
1005 Beaver Grade Road
Moon Township, PA 15108-2944

Re: Peer Review of Invelope system documentation
WJE No. 2008.3871

Dear Keith:

Wiss, Janney, Elstner Associates, Inc. (WJE) is pleased to provide this report to Centria regarding the peer review of the Invelope system details, specification and installation instructions.

Document Review and Report

On November 7, 2008 WJE performed a review of the Invelope details and installation instructions dated June 20, 2008. WJE provided comments that resulted in a revision of some of the details that were resubmitted and dated December 12, 2008. WJE finds this panelized wall system as detailed and specified, generally acceptable for use in many building types and climates; designers using this system should consider the use of the building, the climate it is proposed for, its proposed service life, the integration of other enclosure systems, structural design of the back-up wall, structural inter-story movement and deflection, code compliance and the many variables that influence building design and detailing. Specifications for the system should include the many accessory materials and products proposed as part of the complete system.

Very truly yours,

WISS, JANNEY, ELSTNER ASSOCIATES, INC.



Wagdy Anis, FAIA, LEED AP
Principal